



## **Central Valley Regional Water Quality Control Board**

16 February 2017

Carl Bertram, Manager Vineyard RV Resort, LLC 4985 Midway Road Vacaville, CA 95688 CERTIFIED MAIL 91 7199 9991 7035 8421 0819

RESCISSION OF COVERAGE UNDER WATER QUALITY ORDER 97-10-DWQ-R5060, GENERAL WASTE DISCHARGE REQUIREMENTS FOR DISCHARGES TO LAND BY SMALL DOMESTIC WASTEWATER TREATMENT SYSTEMS, VINEYARD RV RESORT, LLC, VINEYARD RV RESORT, SOLANO COUNTY

On 11 February 2010, the Executive Officer of the Central Valley Regional Water Quality Control Board issued a Notice of Applicability (NOA) granting coverage under the *General Waste Discharge Requirements for Discharges to Land by Small Domestic Wastewater Treatment Systems* (Order 97-10-DWQ-R5060) to Vineyard RV Resort, LLC (the Discharger). The NOA permitted discharges from onsite RVs connected to the domestic wastewater collection system which has a design capacity of 7,950 gallons per day (gpd). Due to a proposed facility expansion, a Report of Waste Discharge (RWD) was requested from the Discharger to update Waste Discharger Requirements (WDRs) for the facility. Upon review of the submitted RWD, dated 2 August 2016, the design capacity for the wastewater treatment system will not change.

The Statewide Onsite Wastewater Treatment System (OWTS) Policy, dated 19 June 2012, allows small domestic systems with flows less than 10,000 gpd to be regulated by Solano County. A letter from the Central Valley Water Board dated 27 September 2016, was sent to the Discharger recommending the wastewater treatment system obtain coverage through Solano County Environmental Health Department. On 27 January 2017, the Discharger submitted a copy of the Solano County Operation and Maintenance Permit, dated 25 January 2017, and a request to rescind the existing NOA. Based on this information, coverage under Order 97-10-DWQ-R5060 is hereby rescinded.

If you have questions, please contact Scott Armstrong at (916) 464-4616 or <a href="mailto:sarmstrong@waterboards.ca.gov">sarmstrong@waterboards.ca.gov</a>.

Executive Officer

cc: Tim O'Brien, State Water Quality Control Board, Sacramento
Jeffery Bell, Solano County Environmental Health Department, Fairfield

KARL E. LONGLEY SCD, P.E., CHAIR | PAMELA C. CREEDON P.E., BCEE, EXECUTIVE OFFICER